


Report of Inspection / Test

Annual NFPA 10

09-08-2026

Property



Print Date: 09-08-2026

Conducted by: [Redacted]

First-Line Fire Extinguisher
1333 N 8th St
Paduch Kentucky 42001
270-554-3473
sales@firstlinefire.com



Portable Fire Extinguishers Inspection List - FIRE EXTINGUISHER GROUP 1

Serial Number	Location	Desc	Barcode	Type	Size	Year of Mfr.	5 Year	6 Year	12 Year	Status	Notes
[Redacted]	Shop			ABC	10#	2024	N/A	2030	2036	Pass	
[Redacted]	Shop			ABC	20#	2024	N/A	2030	2036	Pass	
[Redacted]	Shop			ABC	10#	2026	N/A	2032	2038	Pass	
[Redacted]	Break room			ABC	5#	2021	N/A	2027	2033	Pass	
[Redacted]	Shop			ABC	5#	2021	N/A	2027	2033	Pass	
[Redacted]	Shop			ABC	20#	2024	N/A	2030	2036	Pass	
[Redacted]	Shop			ABC	10#	2021	N/A	2027	2033	Pass	
[Redacted]	Office			ABC	5#	2017	N/A	2035	2029	Pass	
[Redacted]	Office			ABC	5#	2021	N/A	2027	2033	Pass	
[Redacted]	Shop			ABC	10#	2026	N/A	2032	2038	Pass	
[Redacted]	Shop			ABC	10#	2026	N/A	2032	2038	Pass	
[Redacted]	Shop			CO2	15#	2026	2031	N/A	N/A	Pass	

Report of Inspection / Test

Annual NFPA 10

09-08-2026

Property



Print Date: 09-08-2026

Conducted by: [REDACTED]

First-Line Fire Extinguisher

1333 N 8th St

Paduch Kentucky 42001

270-554-3473

sales@firstlinefire.com



Deficiencies - Fire Extinguisher Group 1

None